## **SIEMENS**

## **Data sheet**

6ES7511-1TK01-0AB0



SIMATIC S7-1500T, CPU 1511T-1 PN, Central processing unit with Work memory 225 KB for program and 1 MB for data, 1st interface: PROFINET IRT with 2-port switch, 60 ns bit performance, SIMATIC Memory Card required

General information	
Product type designation	CPU 1511T-1 PN
HW functional status	FS04
Firmware version	V2.9
Product function	
<ul><li>I&amp;M data</li></ul>	Yes; I&M0 to I&M3
• Isochronous mode	Yes; Distributed and central; with minimum OB 6x cycle of 625 $\mu s$ (distributed) and 1 ms (central)
Engineering with	
<ul> <li>STEP 7 TIA Portal configurable/integrated from version</li> </ul>	V17 (FW V2.9) / V14 (FW V2.0) or higher
Configuration control	
via dataset	Yes
Display	
Screen diagonal [cm]	3.45 cm
Control elements	
Number of keys	6
Mode selector switch	1
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes
Mains buffering	
<ul> <li>Mains/voltage failure stored energy time</li> </ul>	5 ms
Repeat rate, min.	1/s
Input current	
Current consumption (rated value)	0.7 A
Inrush current, max.	1.9 A; Rated value
l²t	0.02 A <sup>2</sup> ·s
Power	
Infeed power to the backplane bus	10 W
Power consumption from the backplane bus (balanced)	5.5 W
Power loss	
Power loss, typ.	5.7 W
Memory	
Number of slots for SIMATIC memory card	1
SIMATIC memory card required	Yes
Work memory	
<ul><li>integrated (for program)</li></ul>	225 kbyte

<ul><li>integrated (for data)</li></ul>	1 Mbyte
Load memory	· may to
Plug-in (SIMATIC Memory Card), max.	32 Gbyte
Backup	52 02)to
maintenance-free	Yes
CPU processing times	
for bit operations, typ.	60 ns
for word operations, typ.	72 ns
for fixed point arithmetic, typ.	96 ns
for floating point arithmetic, typ.	384 ns
CPU-blocks	004 110
	4 000; Placks (OR ER EC DR) and LIDTs
Number of elements (total)	4 000; Blocks (OB, FB, FC, DB) and UDTs
Number range	1 60 999; subdivided into: number range that can be used by the
	user: 1 59 999, and number range of DBs created via SFC 86: 60 000 60 999
• Size, max.	1 Mbyte; For DBs with absolute addressing, the max. size is 64 KB
Number range	0 65 535
• Size, max.	150 kbyte
FC	,
Number range	0 65 535
• Size, max.	150 kbyte
OB	
• Size, max.	150 kbyte
Number of free cycle OBs	100
Number of time alarm OBs	20
<ul> <li>Number of delay alarm OBs</li> </ul>	20
Number of cyclic interrupt OBs	20; With minimum OB 3x cycle of 500 μs
Number of process alarm OBs	50
Number of DPV1 alarm OBs	3
<ul> <li>Number of isochronous mode OBs</li> </ul>	2
<ul> <li>Number of technology synchronous alarm OBs</li> </ul>	2
Number of startup OBs	100
Number of asynchronous error OBs	4
Number of synchronous error OBs	2
Number of diagnostic alarm OBs	1
Nesting depth	
per priority class	24
Counters, timers and their retentivity	
S7 counter	
Number	2 048
Retentivity	
— adjustable	Yes
IEC counter	
Number	Any (only limited by the main memory)
Retentivity	, (e.a.) miniou of the monthly
— adjustable	Yes
S7 times	
Number	2 048
Retentivity	
— adjustable	Yes
IEC timer	
Number	Any (only limited by the main memory)
Retentivity	, ( )
— adjustable	Yes
Data areas and their retentivity	
Retentive data area (incl. timers, counters, flags), max.	128 kbyte; In total; available retentive memory for bit memories, timers,
Established waterative with a con- Con-Liting 1997	counters, DBs, and technology data (axes): 88 KB
Extended retentive data area (incl. timers, counters, flags),	1 Mbyte; When using PS 6 0W 24/48/60 V DC HF
max. Flag	
• Size, max.	16 kbyte
Number of clock memories	8; 8 clock memory bit, grouped into one clock memory byte
■ INUITIDEL OF CIOCK ITTERMORTES	o, o clock memory bit, grouped into one clock memory byte

Data blocks	
Retentivity adjustable	Yes
Retentivity adjustable     Retentivity preset	No
Local data	
• per priority class, max.	64 kbyte; max. 16 KB per block
Address area	
Number of IO modules	1 024; max. number of modules / submodules
I/O address area	1 oz i, max. nambor or modalos / odomodalos
• Inputs	32 kbyte; All inputs are in the process image
Outputs	32 kbyte; All outputs are in the process image
per integrated IO subsystem	
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
per CM/CP	
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
Subprocess images	
Number of subprocess images, max.	32
Hardware configuration	
Number of distributed IO systems	32; A distributed I/O system is characterized not only by the integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS-i master modules or links (e.g. IE/PB-Link)
Number of DP masters	
• Via CM	4; A maximum of 4 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total
Number of IO Controllers	
• integrated	1
● Via CM	4; A maximum of 4 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total
Rack	
<ul> <li>Modules per rack, max.</li> </ul>	32; CPU + 31 modules
Number of lines, max.	1
PtP CM	
Number of PtP CMs	the number of connectable PtP CMs is only limited by the number of available slots
Time of day	
Clock	
• Type	Hardware clock
Backup time	6 wk; At 40 °C ambient temperature, typically
Deviation per day, max.  Operating hours aguster.	10 s; Typ.: 2 s
Operating hours counter  • Number	16
Number     Clock synchronization	10
• supported	Yes
• in AS, master	Yes
• in AS, slave	Yes
on Ethernet via NTP	Yes
Interfaces	
Number of PROFINET interfaces	1
1. Interface	
Interface types • RJ 45 (Ethernet)	Yes; X1
Number of ports	2
integrated switch	Yes
Protocols	
IP protocol	Yes; IPv4
PROFINET IO Controller	Yes
PROFINET IO Device	Yes
SIMATIC communication	Yes
Open IE communication	Yes; Optionally also encrypted
Web server	Yes
	Yes
Media redundancy	165

Convigee	
Services	Von
— PG/OP communication	Yes
— Isochronous mode	Yes
Direct data exchange	Yes; Requirement: IRT and isochronous mode (MRPD optional)
— IRT	Yes
— PROFlenergy	Yes; per user program
— Prioritized startup	Yes; Max. 32 PROFINET devices
<ul> <li>Number of connectable IO Devices, max.</li> </ul>	128; In total, up to 256 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
<ul> <li>Of which IO devices with IRT, max.</li> </ul>	64
<ul> <li>Number of connectable IO Devices for RT,</li> </ul>	128
max.	
— of which in line, max.	128
<ul> <li>Number of IO Devices that can be</li> </ul>	8; in total across all interfaces
simultaneously activated/deactivated, max.	
Number of IO Devices per tool, max.	8
<ul> <li>Updating times</li> </ul>	The minimum value of the update time also depends on communication
	share set for PROFINET IO, on the number of IO devices, and on the
Update time for IRT	quantity of configured user data
·	250 µs to 4 ms; Note: In the case of IRT with isochronous mode, the
— for send cycle of 250 μs	minimum update time of 625 µs of the isochronous OB is decisive
— for send cycle of 500 $\mu s$	500 μs to 8 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 625 μs of the isochronous OB is decisive
— for send cycle of 1 ms	1 ms to 16 ms
— for send cycle of 1 ms — for send cycle of 2 ms	2 ms to 32 ms
— for send cycle of 2 ms — for send cycle of 4 ms	4 ms to 64 ms
•	Update time = set "odd" send clock (any multiple of 125 $\mu$ s: 375 $\mu$ s, 625
<ul> <li>With IRT and parameterization of "odd" send cycles</li> </ul>	Update time = set "odd" send clock (any multiple of 125 $\mu$ s: 375 $\mu$ s, 625 $\mu$ s 3 875 $\mu$ s)
Update time for RT	до о от о ро <sub>ј</sub>
— for send cycle of 250 µs	250 μs to 128 ms
— for send cycle of 250 μs — for send cycle of 500 μs	500 µs to 256 ms
,	1 ms to 512 ms
— for send cycle of 1 ms	
— for send cycle of 2 ms	2 ms to 512 ms
— for send cycle of 4 ms	4 ms to 512 ms
PROFINET IO Device	
Services	Vac
— PG/OP communication	Yes
— Isochronous mode	No Was
— IRT	Yes
— PROFlenergy	Yes; per user program
— Shared device	Yes
Number of IO Controllers with shared device,	4
max.	V
activation/deactivation of I-devices	Yes; per user program
Asset management record	Yes; per user program
Interface types	
RJ 45 (Ethernet)	
• 100 Mbps	Yes
Autonegotiation	Yes
Autocrossing	Yes
Industrial Ethernet status LED	Yes
Protocols	
PROFIsafe	No
Number of connections	
Number of connections, max.	96; via integrated interfaces of the CPU and connected CPs / CMs
Number of connections, max.     Number of connections reserved for ES/HMI/web	10
	64
Number of S7 routing paths	
Number of S7 routing paths  Padundanay made	16
Redundancy mode	Voc
H-Sync forwarding     Madia and an artists	Yes
Media redundancy	
Maratia and the	
— Media redundancy	only via 1st interface (X1)
<ul><li>— Media redundancy</li><li>— MRP</li></ul>	only via 1st interface (X1)  Yes; MRP Automanager according to IEC 62439-2 Edition 2.0, MRP  Manager; MRP Client

<ul> <li>MRP interconnection, supported</li> </ul>	Yes; as MRP ring node according to IEC 62439-2 Edition 3.0
— MRPD	Yes; Requirement: IRT
<ul> <li>Switchover time on line break, typ.</li> </ul>	200 ms; For MRP, bumpless for MRPD
Number of stations in the ring, max.	50
SIMATIC communication	
PG/OP communication	Yes; encryption with TLS V1.3 pre-selected
• S7 routing	Yes
S7 communication, as server	Yes
S7 communication, as client	Yes
User data per job, max.  Open IE communication	See online help (S7 communication, user data size)
TCP/IP	Yes
— Data length, max.	64 kbyte
several passive connections per port,	Yes
supported	100
• ISO-on-TCP (RFC1006)	Yes
— Data length, max.	64 kbyte
• UDP	Yes
<ul><li>— Data length, max.</li></ul>	2 kbyte; 1 472 bytes for UDP broadcast
<ul><li>UDP multicast</li></ul>	Yes; Max. 5 multicast circuits
• DHCP	Yes
• DNS	Yes
• SNMP	Yes
• DCP	Yes
• LLDP	Yes
Encryption	Yes; Optional
Web server	
• HTTP	Yes; Standard and user pages
• HTTPS	Yes; Standard and user pages
OPC UA	V 10 11111
Runtime license required     ORC LIA Client	Yes; "Small" license required
OPC UA Client  Application authoritisation	Yes Yes
<ul><li>— Application authentication</li><li>— Security policies</li></ul>	Available security policies: None, Basic128Rsa15, Basic256Rsa15,
— Security policies	Basic256Sha256
<ul> <li>User authentication</li> </ul>	"anonymous" or by user name & password
<ul> <li>Number of connections, max.</li> </ul>	4
<ul> <li>Number of nodes of the client interfaces,</li> </ul>	1 000
recommended max.	
<ul> <li>Number of elements for one call of OPC_UA_NodeGetHandleList/OPC_UA_ReadList/C max.</li> </ul>	300
Number of elements for one call of OPC_UA_NameSpaceGetIndexList, max.	20
Number of elements for one call of	100
OPC_UA_MethodGetHandleList, max.	
<ul> <li>Number of simultaneous calls of the client instructions for session management, per connection, max.</li> </ul>	1
Number of simultaneous calls of the client instructions for data access, per connection, max.	5
Number of registerable nodes, max.	5 000
Number of registerable method calls of	100
OPC_UA_MethodCall, max.	
<ul> <li>Number of inputs/outputs when calling OPC_UA_MethodCall, max.</li> </ul>	20
OPC UA Server	Yes; Data access (read, write, subscribe), method call, custom address space
<ul> <li>Application authentication</li> </ul>	Yes
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
<ul><li>User authentication</li></ul>	"anonymous" or by user name & password
<ul> <li>— GDS support (certificate management)</li> </ul>	Yes
— Number of sessions, max.	32
Number of accessible variables, max.	50 000
Number of registerable nodes, max.	10 000
<ul> <li>Number of subscriptions per session, max.</li> </ul>	20

Compliant internal aris	100
— Sampling interval, min.	100 ms
— Publishing interval, min.	500 ms
Number of server methods, max.	20
<ul> <li>Number of inputs/outputs per server method, max.</li> </ul>	20
Number of monitored items, recommended max.	1 000; for 1 s sampling interval and 1 s send interval
Number of server interfaces, max.	10 of each "Server interfaces" / "Companion specification" type and 20
<ul> <li>Number of nodes for user-defined server interfaces, max.</li> </ul>	of the type "Reference namespace" 1 000
Alarms and Conditions	Yes
Number of program alarms	100
Number of alarms for system diagnostics	50
Further protocols	
• MODBUS	Yes; MODBUS TCP
Isochronous mode	
Equidistance	Yes
S7 message functions	
	20
Number of login stations for message functions, max.	32 Voc
Program alarms	Yes 5 000: Program messages are generated by the "Program Alarm"
Number of configurable program messages, max.	5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH
Number of loadable program messages in RUN, max.	2 500
Number of ioadable program messages in Norv, max.  Number of simultaneously active program alarms	- ***
Number of program alarms	600
Number of program alarms     Number of alarms for system diagnostics	100
Number of alarms for motion technology objects	80
Test commissioning functions	
	Vac Davillal culing access receible for up to E anxincation systems
Joint commission (Team Engineering)	Yes; Parallel online access possible for up to 5 engineering systems
Status block	Yes; Up to 8 simultaneously (in total across all ES clients)
Single step	No
Number of breakpoints Status/control	8
Status/control variable	Yes
Variables	Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters
Number of variables, max.	inputs/outputs, memory bits, DBs, distributed 1/Os, timers, counters
of which status variables, max.	200; per job
of which control variables, max.	200; per job
Forcing	200, per jub
• Forcing	Yes
Forcing     Forcing, variables	Peripheral inputs/outputs
Number of variables, max.	200
Diagnostic buffer	200
• present	Yes
Number of entries, max.	1 000
— of which powerfail-proof	500
Traces	
Number of configurable Traces	4; Up to 512 KB of data per trace are possible
Interrupts/diagnostics/status information	
Diagnostics indication LED	
RUN/STOP LED	Yes
• ERROR LED	Yes
MAINT LED	Yes
Connection display LINK TX/RX	Yes
Supported technology objects	
Motion Control	Ves: Note: The number of technology chiects affects the cycle time of
WOUTH CONTROL	Yes; Note: The number of technology objects affects the cycle time of the PLC program; selection guide via the TIA Selection Tool
<ul> <li>Number of available Motion Control resources for</li> </ul>	800
technology objects	
Required Motion Control resources	
— per speed-controlled axis	40
<ul> <li>per positioning axis</li> </ul>	80
<ul><li>— per positioning axis</li><li>— per synchronous axis</li></ul>	

— per external encoder	**
•	80
— per output cam	20
— per cam track	160
— per probe	40
<ul> <li>Number of available Extended Motion Control resources for technology objects</li> </ul>	40
<ul> <li>Required Extended Motion Control resources</li> </ul>	
— per cam (1 000 points and 50 segments)	2
— per cam (10 000 points and 50 segments)	20
— for each set of kinematics	30
<ul> <li>Per leading axis proxy</li> </ul>	3
Positioning axis	
Number of positioning axes at motion control	5
cycle of 4 ms (typical value)	·
<ul> <li>Number of positioning axes at motion control cycle of 8 ms (typical value)</li> </ul>	10
Controller	
<ul><li>PID_Compact</li></ul>	Yes; Universal PID controller with integrated optimization
PID_3Step	Yes; PID controller with integrated optimization for valves
PID-Temp	Yes; PID controller with integrated optimization for temperature
Counting and measuring	
High-speed counter	Yes
Ambient conditions	
Ambient temperature during operation	0.00
horizontal installation, min.	0 °C  60 °C: Diaplay: F0 °C, at an apparating temporature of typically F0 °C, the
<ul> <li>horizontal installation, max.</li> </ul>	60 °C; Display: 50 °C, at an operating temperature of typically 50 °C, the display is switched off
<ul> <li>vertical installation, min.</li> </ul>	0 °C
<ul> <li>vertical installation, max.</li> </ul>	40 °C; Display: 40 °C, at an operating temperature of typically 40 °C, the display is switched off
Ambient temperature during storage/transportation	
• min.	-40 °C
• max.	70 °C
Altitude during operation relating to sea level	
Installation altitude above sea level, max.	5 000 m; Restrictions for installation altitudes > 2 000 m, see manual
configuration / header	
configuration / programming / header	
Programming language	
— LAD	Yes
— FBD	Yes
— STL	Yes
100	
— SCL	Yes
— GRAPH	
— GRAPH Know-how protection	Yes Yes
— GRAPH  Know-how protection  • User program protection/password protection	Yes Yes
— GRAPH  Know-how protection  • User program protection/password protection  • Copy protection	Yes Yes Yes
— GRAPH  Know-how protection      • User program protection/password protection     • Copy protection     • Block protection	Yes Yes
— GRAPH  Know-how protection      • User program protection/password protection     • Copy protection     • Block protection  Access protection	Yes Yes Yes Yes Yes Yes
— GRAPH  Know-how protection      • User program protection/password protection     • Copy protection     • Block protection  Access protection  • protection of confidential configuration data	Yes Yes Yes Yes Yes Yes Yes
— GRAPH  Know-how protection      • User program protection/password protection     • Copy protection     • Block protection  Access protection  protection of confidential configuration data     • Password for display	Yes Yes Yes Yes Yes Yes Yes Yes
— GRAPH  Know-how protection      • User program protection/password protection     • Copy protection     • Block protection  Access protection  • protection of confidential configuration data	Yes Yes Yes Yes Yes Yes Yes
— GRAPH  Know-how protection  • User program protection/password protection  • Copy protection  • Block protection  Access protection  • protection of confidential configuration data  • Password for display  • Protection level: Write protection  • Protection level: Read/write protection	Yes Yes Yes Yes Yes Yes Yes Yes
GRAPH Know-how protection  • User program protection/password protection  • Copy protection  • Block protection  Access protection  • protection of confidential configuration data  • Password for display  • Protection level: Write protection	Yes Yes Yes Yes Yes Yes Yes Yes Yes
— GRAPH  Know-how protection  • User program protection/password protection  • Copy protection  • Block protection  Access protection  • protection of confidential configuration data  • Password for display  • Protection level: Write protection  • Protection level: Read/write protection	Yes
— GRAPH  Know-how protection  • User program protection/password protection  • Copy protection  • Block protection  Access protection  • protection of confidential configuration data  • Password for display  • Protection level: Write protection  • Protection level: Read/write protection  • Protection level: Complete protection	Yes
— GRAPH  Know-how protection  • User program protection/password protection  • Copy protection  • Block protection  Access protection  • protection of confidential configuration data  • Password for display  • Protection level: Write protection  • Protection level: Read/write protection  • Protection level: Complete protection  programming / cycle time monitoring / header	Yes
— GRAPH  Know-how protection  User program protection/password protection  Copy protection  Block protection  Access protection  protection of confidential configuration data  Password for display  Protection level: Write protection  Protection level: Read/write protection  Protection level: Complete protection  programming / cycle time monitoring / header  lower limit	Yes
— GRAPH  Know-how protection  • User program protection/password protection  • Copy protection  • Block protection  Access protection  • protection of confidential configuration data  • Password for display  • Protection level: Write protection  • Protection level: Read/write protection  • Protection level: Complete protection  programming / cycle time monitoring / header  • lower limit  • upper limit  Dimensions	Yes
— GRAPH  Know-how protection  • User program protection/password protection  • Copy protection  • Block protection  Access protection  • protection of confidential configuration data  • Password for display  • Protection level: Write protection  • Protection level: Read/write protection  • Protection level: Complete protection  programming / cycle time monitoring / header  • lower limit  • upper limit  Dimensions  Width	Yes
— GRAPH  Know-how protection  • User program protection/password protection  • Copy protection  • Block protection  Access protection  • protection of confidential configuration data  • Password for display  • Protection level: Write protection  • Protection level: Read/write protection  • Protection level: Complete protection  programming / cycle time monitoring / header  • lower limit  • upper limit  Dimensions  Width  Height	Yes
— GRAPH  Know-how protection  User program protection/password protection  Copy protection  Block protection  Access protection  protection of confidential configuration data  Password for display  Protection level: Write protection  Protection level: Read/write protection  Protection level: Complete protection  programming / cycle time monitoring / header  lower limit  upper limit  Dimensions  Width  Height  Depth	Yes
— GRAPH  Know-how protection  • User program protection/password protection  • Copy protection  • Block protection  Access protection  • protection of confidential configuration data  • Password for display  • Protection level: Write protection  • Protection level: Read/write protection  • Protection level: Complete protection  programming / cycle time monitoring / header  • lower limit  • upper limit  Dimensions  Width  Height	Yes

