



C/N: 10310001095

Programmable Logic Controller 설치 가이드

XGB CPU
(E타입)XB(E)C-DR10/14/20/30E
XB(E)C-DN10/14/20/30E
XB(E)C-DP10/14/20/30E

이 설치 가이드는 PLC제어를 위해 간략한 동작 설명을 제공합니다. 제품을 사용하기 전에 안전을 위한 주의 사항 등을 반드시 읽고 정확하게 사용하여 주십시오.

1 안전을 위한 주의사항

■ 경고/주의 표기의 의미

| | | |
|--|-----------|--|
| | 경고 | 취급을 잘못할 경우 사용자가 사망 또는 중상을 입을 위험이 예상되는 경우 |
| | 주의 | 취급을 잘못할 경우 사용자가 상해를 입거나 또는 물질 손해만 발생하는 위험이 예상되는 경우 |

⚠ 경고

- 전원이 인가된 상태에서 단자대를 만지지 마십시오.
- 제품 내부의 금속성 이물질이 유입되지 않도록 하여 주십시오.
- 배터리는 충전, 분해, 가열, Short, 솔더링 등을 하지 마십시오.

⚠ 주의

- 제품의 정격전압과 단자 배열을 확인한 후 정확하게 배선하여 주십시오.
- 배선 시 단자의 나사를 규정 토크로 단단하게 조여 주십시오.
- 가연성 물질이 있는 주변에 설치하지 마십시오.
- 제품에 직접 진동이 인가되지 않도록 하십시오.
- 전문 서비스원 외에는 제품을 분해, 수리 또는 개조하지 마십시오.
- 사용설명서와 데이터시트에 명기된 일반규격의 조건에서 사용해 주십시오.
- 출력단에 연결하는 부하는 규정된 정격 이내의 것을 사용하십시오.
- 제품과 배터리를 폐기할 경우 산업 폐기물로 처리하여 주십시오.

2 사용 환경에 대하여

설치 시 아래 환경 조건을 준수하여 주시기 바랍니다.

| No | 항목 | 규격 | 관련규격 | | | | |
|-------------|----------------------------|-----------------------|--------------------------|------------------------|-------------|-------|----|
| 1 | 사용온도 | 0℃ ~ 55℃ | - | | | | |
| 2 | 보관온도 | -25℃ ~ 70℃ | - | | | | |
| 3 | 사용습도 | 5~95%RH, 이슬이 맺히지 않을 것 | - | | | | |
| 4 | 보관습도 | 5~95%RH, 이슬이 맺히지 않을 것 | - | | | | |
| 5 | 내진동 | 단속적인 진동이 있는 경우 | | X, Y, Z 각 방향 10회 | IEC 61131-2 | | |
| | | 주파수 | 가속도 | | | 진폭 | 횡수 |
| | | 5sf<8.4Hz | - | | | 3.5mm | - |
| | | 8.4sf≤150Hz | 9.8m/s ² (1g) | | | - | - |
| | | 연속적인 진동이 있는 경우 | | | | | |
| | | 주파수 | 가속도 | | | 진폭 | |
| 5sf<8.4Hz | - | 1.75mm | | | | | |
| 8.4sf≤150Hz | 4.9m/s ² (0.5g) | - | | | | | |

3 성능규격

XGB 기본 유닛의 성능규격입니다.

자세한 설명은 해당제품의 사용설명서를 참조하십시오

| 항목 | 규격 | | |
|---------------|--|---|--|
| 연산방식 | 반복 연산, 정주기 연산 인터럽트 연산, 고정주기 스캔 | | |
| 입출력 제어방식 | 스캔 동기 일괄처리 방식(리프레시 방식), 명령어에 의한 다이렉트 방식 | | |
| 연산 속도 (기본 명령) | 0.24μs/step | | |
| 최대 증설 단수 | 기본+옵션(옵션1단: 10/14점, 옵션2단: 20/30점) | | |
| 태스크 | 초기화 | 1개 | |
| | 정주기 | 최대 8개 | |
| | 외부 접점 | 최대 4개 | |
| | 내부 디바이스 | 최대 8개 | |
| 운전 모드 | RUN, STOP | | |
| 자기 진단 | 연산 지연 감시, 메모리 이상, 입출력 이상 | | |
| 프로그램 포트 | RS-232C(Loader) | | |
| 정전 시 데이터 보존방법 | 기본 파라미터에서 래치(리테인) 영역 설정 | | |
| 내장 기능 | Cnet I/F | 전용 프로토콜 지원 모드버스 프로토콜 지원 사용자 정의 프로토콜 지원 RS-232C 1포트, RS-485 1 포트 중 파라미터에 의해 1포트 선택 | |
| | 고속 카운터 | 성능 | 1상 : 4kHz 4채널 2상 : 2kHz 2채널 |
| | | 카운터모드 | 입력 펄스와 가감산 방식에 따라 4가지의 카운터 모드 지원 •1상 펄스 입력 시 가감산 카운터 •1상 펄스 입력 시 B상 입력에 의한 가감산 카운터 •2상 펄스 입력 시 가감산 펄스 입력 카운터 •2상 펄스 입력시 상승/하강펄스 위상차에 의한 가감산카운터 |
| | | 연산 | 32bit signed 카운터 |
| | 부가기능 | 내부/외부 프리셋 기능, 래치 카운터 기능 비교 출력 기능, 단위시간당 회전수 기능 | |
| 펄스 캐치 | 50μs 4점 | | |
| 외부접점인터럽트 | 4점 : 50μs | | |
| 입력 필터 | 1,3,5,10,20,70,100ms중 선택(제품별 선택 가능) | | |

4 사용 가능한 버전

■ 시스템 구성 시 아래와 같은 버전을 사용해야 정상적인 동작이 가능합니다.

- 1) XG5000 Software : V4.01 이상


5 주변기기의 확인 (별도구매)

■ 제품 사용 시 필요한 주변기기를 확인하여 주십시오.

- 1) PMC-310S : RS-232C 접속(다운로드) 케이블

6 제품의 각 부 명칭 및 외형치수 (mm)

■ 제품의 전면부에 대한 설명입니다. 각 부의 명칭을 참조하여 시스템 운전 시 참조하시기 바랍니다. 자세한 설명은 사용설명서를 참조하십시오.




- | | | |
|---------------|------------------|---------------|
| ① 내장통신 접속 단자대 | ② 입력 단자대 | ③ 상태 표시LED |
| ④ 입력 표시용LED | ⑤ 출력 표시용LED | ⑥ 옵션 보드 홀더 |
| ⑦ O/S 모드 디스위치 | ⑧ RUN/STOP 모드스위치 | ⑨ PADT접속용 커넥터 |
| ⑩ 전원 단자대 | ⑪ 출력 단자대 | ⑫ 24V출력(보조전원) |

■ 외형치수(mm)

| 제품 | W | D | H |
|-----------------------|-----|----|----|
| XB(E)C-DR(N)(P)10/14E | 97 | 64 | 90 |
| XB(E)C-DR(N)(P)20/30E | 135 | 64 | 90 |

7 배선

■ 전원 배선



- 1) 전원 변동이 규정 값 범위보다 큰 경우에는 정전압 트랜스포머를 접속하여 주십시오.
- 2) 선간 및 대지간 노이즈가 작은 전원을 연결하여 주십시오. 노이즈가 많은 경우 절연 트랜스포머를 접속하여 주십시오
- 3) PLC의 전원부와 입출력부 및 기타기기는 계통을 분리하여 주십시오.
- 4) 접지배선은 3종접지(접지저항 100Ω이하)를 하며 접지용 전선을 2mm²이상의 것을 사용하여 주십시오. 단, 접지에 따라 오동작하는 경우 접지를 분리하여 주십시오.

8 보증 내용

■ 보증 기간

구입하신 제품의 보증 기간은 제조 일로부터 18개월입니다.

■ 보증 외 범위

- 1) 사용설명서에 명기된 이외의 부적당한 조건·환경·취급으로 발생한 경우
- 2) 고장의 원인이 당사의 제품 이외의 것으로 발생한 경우
- 3) 당사와 당사가 정한 지정점 이외의 장소에서 개조와 수리를 한 경우
- 4) 제품 본래의 사용 방법이 아닌 경우
- 5) 당사에서 출하 시 과학·기술의 수준에서는 예상이 불가능한 사유에 의한 경우
- 6) 기타 천재·화재 등 당사 측에 책임이 없는 경우

■ 제품 규격의 변경

제품 성능 개선을 위해 설치가이드의 내용은 사전 예고 없이 변경될 수 있습니다.

LS ELECTRIC Co., Ltd. 10310001095 V4.4 (2022.9)

한번 맺은 인연을
가장 소중히
여깁니다!

- 서비스 대표 전화 (전국 어디서나)
1544-2080

■ 구입 문의

| | | |
|----------|----------------------|-------------------|
| 서울영업 | TEL:(02)2034-4623~38 | FAX:(02)2034-4057 |
| 부산영업 | TEL:(051)310-6855~60 | FAX:(051)310-6851 |
| 대구영업 | TEL:(053)603-7741~8 | FAX:(053)603-7788 |
| 서부영업(광주) | TEL:(062)510-1891~92 | FAX:(062)526-3262 |
| 서부영업(대전) | TEL:(042)820-4240~42 | FAX:(042)820-4298 |

- 제조사(공장): 충남 천안시 동남구 목천읍 삼성4길 56 (우 31226)



Programmable Logic Controller Installation Guide

XGB CPU
(E-type)

XB(E)C-DR10/14/20/30E
XB(E)C-DN10/14/20/30E
XB(E)C-DP10/14/20/30E

This installation guide provides simple function information of PLC control. Please carefully read this data sheet and manuals before using products. Especially read safety precautions and handle the products properly.

1 Safety Precautions

■ Meaning of warning and caution inscription

| | | |
|--|----------------|--|
| | WARNING | WARNING indicates a potentially hazardous situation which, if not avoided, could result in death or serious injury |
| | CAUTION | CAUTION indicates a potentially hazardous situation which, if not avoided, may result in minor or moderate injury. It may also be used to alert against unsafe practices |

| WARNING | |
|---------|--|
| ① | Do not contact the terminals while the power is applied. |
| ② | Protect the product from being gone into by foreign metallic matter. |
| ③ | Do not manipulate the battery (charge, disassemble, hitting, short, soldering) |
| CAUTION | |
| ① | Be sure to check the rated voltage and terminal arrangement before wiring |
| ② | When wiring, tighten the screw of terminal block with the specified torque range |
| ③ | Do not install the flammable things on surroundings |
| ④ | Do not use the PLC in the environment of direct vibration |
| ⑤ | Except expert service staff, Do not disassemble or fix or modify the product |
| ⑥ | Use the PLC in an environment that meets the general specifications contained in this datasheet. |
| ⑦ | Be sure that external load does not exceed the rating of output module. |
| ⑧ | When disposing of PLC and battery, treat it as industrial waste. |

2 Operating Environment

To install, observe the below conditions.

| No | Item | Specification | Standard | | | |
|-------------|----------------------------|---------------------------|--------------------------|--|-------------|-----------|
| 1 | Ambient temp. | 0 ~ 55℃ | - | | | |
| 2 | Storage temp. | -25 ~ 70℃ | - | | | |
| 3 | Ambient humidity | 5 ~ 95%RH, non-condensing | - | | | |
| 4 | Storage humidity | 5 ~ 95%RH, non-condensing | - | | | |
| 5 | Vibration Resistance | Occasional vibration | | 10 times in each direction for X, Y, Z | IEC 61131-2 | |
| | | Frequency | Acceleration | | | Amplitude |
| | | 5≤f<8.4Hz | - | | | 3.5mm |
| | | 8.4≤f≤150Hz | 9.8m/s ² (1g) | | | - |
| | | Continuous vibration | | | | |
| | | Frequency | Frequency | | | Amplitude |
| 5≤f<8.4Hz | - | 1.75mm | | | | |
| 8.4≤f≤150Hz | 4.9m/s ² (0.5g) | - | | | | |

3 Performance specifications

This is Performance specification of XGB. For more details, refer to related manual.

| Item | Specification | | |
|--------------------------------------|---|--|---|
| Operation method | Reiterative operation, fixed cycle operation, Interrupt operation, constant period scan | | |
| I/O control method | Scan synchronous batch processing (refresh method) Direct method by instruction | | |
| Operation speed | Basic instruction: 0.24μs/step | | |
| Max expansion slot | Main+Option (option 1slot: 10/14 point type, option 2slot: 20/30 point type) | | |
| task | Initialization | 1 | |
| | Fixed cycle | 1 | |
| | External point | Max. 8 | |
| | Internal device | Max. 4 | |
| Operating mode | RUN, STOP | | |
| Self-diagnosis | Delay of operation, abnormal memory, abnormal I/O | | |
| Program port | RS-232C(Loader) | | |
| Data keeping method at power failure | Setting latch area at basic parameter | | |
| Built-in Function | Cnet I/F function | Dedicated protocol, Modbus protocol User defined protocol | |
| | | Selects one port between RS-232C 1 port and RS-485 1 port by parameter | |
| | High Speed Counter | Performance | 1-phase : 4kHz 4 channels 2-phase : 2kHz 2 channels |
| | | Counter mode | 4 counter modes are supported based on input pulse and INC/DEC method • 1 pulse operation Mode : INC/DEC count by program • 1 pulse operation Mode : INC/DEC count by phase B pulse input • 2 pulse operation Mode : INC/DEC count by input pulse • 2 pulse operation Mode : INC/DEC count by difference of phase |
| | | operation | 32bit signed counter |
| | Function | • Internal/external preset • Latch counter • Compare output • No. of rotation per unit time | |
| | Pulse catch | 50μs 4 points | |
| | External point interrupt | 4 points: 50μs | |
| | Input filter | Selects among 1,3,5,10,20,70,100ms (For each module) | |

4 Applicable Support Software


- For system configuration, the following version is necessary.
 - 1) XG5000 Software : V4.01 or above

5 Accessories and Cable Specifications

- Check the accessory (Order the cable if needed)
 - 2) PMC-310S : RS-232 connecting (download) cable.

6 Parts name and Dimension (mm)

■ This is front part of the CPU. Refer to each name when driving the system. For more information, refer to user manual.




- ① Built-in Communication Terminal block
- ② Input terminal block
- ③ Operation status LED
- ④ Input status LED
- ⑤ Output status LED
- ⑥ Option board holder
- ⑦ O/S mode dip switch
- ⑧ RUN/STOP mode switch
- ⑨ PADT Connector
- ⑩ Power terminal block
- ⑪ Output terminal block
- ⑫ 24V Output (sub-power)

■ Dimension(mm)

| Module | W | D | H |
|-----------------------|-----|----|----|
| XB(E)C-DR(N)(P)10/14E | 97 | 64 | 90 |
| XB(E)C-DR(N)(P)20/30E | 135 | 64 | 90 |

7 Wiring

■ Power wiring



- 1) In case that the power change is larger than the range of standard, connect constant voltage transformer
- 2) Connect the power having the small noise between cables or between earths. In case of having lots of noise, connect the isolating transformer or noise filter.
- 3) power for PLC, I/O device and other machines should be separate.
- 4) Use the dedicated earth if possible. In case of Earth works, use 3 class earth (earth resistance 100 Ω or less) and Use more than 2 mm² cable for earth. If the abnormal operation is found according to the earth, separate the earth

8 Warranty

- Warranty period
 - 18 months after the production date.
- Scope of Warranty
 - 18-month warranty is available except:
 - 1) The troubles caused by improper condition, environment, or treatment except the instructions of LS ELECTRIC.
 - 2) The troubles caused by external devices
 - 3) The troubles caused by remodeling or repairing based on the user's own discretion.
 - 4) The troubles caused by improper usage of the product
 - 5) The troubles caused by the reason which exceeded the expectation from science and technology level when LS ELECTRIC manufactured the product
 - 6) The troubles caused by natural disaster
- Change in specifications
 - Product specifications are subject to change without notice due to continuous product development and improvement.

LS ELECTRIC Co., Ltd. 10310001095 V4.4 (2022.9)



- Headquarter/Seoul Office Tel: 82-2-2034-4033,4888,4703
- LS ELECTRIC Shanghai Office (China) Tel: 86-21-5237-9977
- LS ELECTRIC (Wuxi) Co., Ltd. (Wuxi, China) Tel: 86-510-6851-6666
- LS-ELECTRIC Vietnam Co., Ltd. (Hanoi, Vietnam) Tel: 84-93-631-4099
- LS ELECTRIC Middle East FZE (Dubai, U.A.E.) Tel: 971-4-886-5360
- LS ELECTRIC Europe B.V. (Hoofddorf, Netherlands) Tel: 31-20-654-1424
- LS ELECTRIC Japan Co., Ltd. (Tokyo, Japan) Tel: 81-3-6268-8241
- LS ELECTRIC America Inc. (Chicago, USA) Tel: 1-800-891-2941
- Factory: 56, Samseong 4-gil, Mokcheon-eup, Dongnam-gu, Cheonan-si, Chungcheongnam-do, 31226, Korea